

ELECTRICAL CERTIFICATE OF INSPECTION

EL: Final Assessment

ACTIVITY DATE: May 29, 2015

CONTACT INFORMATION:

Vincent Emery dba Emery Electrical & Electronic Systems
160 YORKTON AVENUE
PENTICTON BC V2A 3V2

CONTRACTOR / FSR INFORMATION:

Vincent Emery

SITE ADDRESS:

#83-8487 HWY 97 COUNTRY PINES MHP
OLIVER BC V0H 1T2

Inspection Result: Passed

Applicable when checked

Do Not Energize

Authorized for Connection

Existing Service Connection

Do Not Cover

Authorized for Cover

Items	Comments	Compliant	Not Compliant
Main distribution	Existing 100A 40 cir comb ITE panel board	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Branch circuits	All Type NMD90 cabling	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Outlets	To residential standards	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Motor circuits	AC unit, exterior switch secured as required	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Fixtures and Fittings	All fixtures and devices installed, GFCI protection provided to all exterior receptacles	<input checked="" type="checkbox"/>	<input type="checkbox"/>

SAFETY OFFICER NOTES

Re: Used Mobile Home bears acceptable CSA certification label. This inspection authorizes the work done to install the addition.

All wiring OK

This Mobile Home is authorized for sale under provisions of the BC Safety Standards Act



Permit Number: EL-228937-2015
Inspection Number: ELIN-353157-2015
(When inquiring always refer to these numbers.)

GENERAL REQUIREMENTS & INFORMATION

1. All non-compliances must be resolved by the date indicated on this Certificate Of Inspection.
2. The BC Safety Authority is to be notified of any incident that results in an injury to any person or damage to the regulated equipment.
To report an incident, go to www.safetyauthority.ca (search: "report an incident")
3. When an Operating Permit is required, the installation owner has 60 days to obtain a valid Operating Permit following a Passed Final Assessment

Safety Officer Name: Ted Gilbert
Safety Officer Phone: 250-488-0699
Safety Officer Email: Ted.Gilbert@safetyauthority.ca

If you disagree with this Certificate of Inspection, you may request, in writing, a Safety Manager review within 30 days from the date of issue. A Review Request Form can be obtained from any BC Safety Authority office or online at: www.safetyauthority.ca (search: "manager review")

For information on the Safety Standards Act, Regulations, and the Review/Appeal process, please visit www.safetyauthority.ca