



CERTIFICATE OF ANALYSIS

REPORTED TO	Century 21 Horizon West (Princeton) PO Box 880, 224 Bridge Street Princeton, BC V0X 1W0		
ATTENTION	Lee Mowry	WORK ORDER	22B0823
PO NUMBER		RECEIVED / TEMP	2022-02-05 12:50 / 8.4°C
PROJECT	Analysis for Lee Mowry	REPORTED	2022-02-14 14:27
PROJECT INFO		COC NUMBER	No Number

Introduction:

CARO Analytical Services is a testing laboratory full of smart, engaged scientists driven to make the world a safer and healthier place. Through our clients' projects we become an essential element for a better world. We employ methods conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts. CARO is accredited by the Canadian Association for Laboratories Accreditation (CALA) to ISO/IEC 17025:2017 for specific tests listed in the scope of accreditation approved by CALA.

Big Picture Sidekicks



We've Got Chemistry



Ahead of the Curve



You know that the sample you collected after snowshoeing to site, digging 5 meters, and racing to get it on a plane so you can submit it to the lab for time sensitive results needed to make important and expensive decisions (whew) is VERY important. We know that too.

It's simple. We figure the more you enjoy working with our fun and engaged team members; the more likely you are to give us continued opportunities to support you.

Through research, regulation knowledge, and instrumentation, we are your analytical centre for the technical knowledge you need, BEFORE you need it, so you can stay up to date and in the know.


If you have any questions or concerns, please contact me at teamcaro@caro.ca

Authorized By:

Team CARO
Client Service Representative

1-888-311-8846 | www.caro.ca

#110 4011 Viking Way Richmond, BC V6V 2K9 | #102 3677 Highway 97N Kelowna, BC V1X 5C3 | 17225 109 Avenue Edmonton, AB T5S 1H7 | #108 4475 Wayburne Drive Burnaby, BC V5G 4X4




TEST RESULTS

REPORTED TO Century 21 Horizon West (Princeton)
PROJECT Analysis for Lee Mowry

WORK ORDER 22B0823
REPORTED 2022-02-14 14:27

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
175 Link Lake Road Essential Drinking Water Test (22B0823-01) Matrix: Water Sampled: 2022-02-05 10:00						
Anions						
Chloride	0.50	AO ≤ 250	0.10	mg/L	2022-02-05	
Fluoride	< 0.10	MAC = 1.5	0.10	mg/L	2022-02-05	
Nitrate (as N)	0.022	MAC = 10	0.010	mg/L	2022-02-05	
Nitrite (as N)	< 0.010	MAC = 1	0.010	mg/L	2022-02-05	
Sulfate	4.4	AO ≤ 500	1.0	mg/L	2022-02-05	
Calculated Parameters						
Hardness, Total (as CaCO ₃)	68.6	None Required	0.500	mg/L	N/A	
Solids, Total Dissolved	112	AO ≤ 500	1.00	mg/L	N/A	
General Parameters						
Alkalinity, Total (as CaCO ₃)	116	N/A	1.0	mg/L	2022-02-08	
Alkalinity, Phenolphthalein (as CaCO ₃)	< 1.0	N/A	1.0	mg/L	2022-02-08	
Alkalinity, Bicarbonate (as CaCO ₃)	116	N/A	1.0	mg/L	2022-02-08	
Alkalinity, Carbonate (as CaCO ₃)	< 1.0	N/A	1.0	mg/L	2022-02-08	
Alkalinity, Hydroxide (as CaCO ₃)	< 1.0	N/A	1.0	mg/L	2022-02-08	
Conductivity (EC)	182	N/A	2.0	µS/cm	2022-02-08	
Cyanide, Total	< 0.0020	MAC = 0.2	0.0020	mg/L	2022-02-11	
pH	7.84	7.0-10.5	0.10	pH units	2022-02-08	HT2
Turbidity	5.25	OG < 1	0.10	NTU	2022-02-08	
Microbiological Parameters						
Coliforms, Total	< 1	MAC = 0	1	CFU/100 mL	2022-02-05	
E. coli	< 1	MAC = 0	1	CFU/100 mL	2022-02-05	
Total Metals						
Aluminum, total	0.0070	OG < 0.1	0.0050	mg/L	2022-02-11	
Antimony, total	< 0.00020	MAC = 0.006	0.00020	mg/L	2022-02-11	
Arsenic, total	< 0.00050	MAC = 0.01	0.00050	mg/L	2022-02-11	
Barium, total	0.0119	MAC = 2	0.0050	mg/L	2022-02-11	
Boron, total	< 0.0500	MAC = 5	0.0500	mg/L	2022-02-11	
Cadmium, total	0.000014	MAC = 0.005	0.000010	mg/L	2022-02-11	
Calcium, total	21.4	None Required	0.20	mg/L	2022-02-11	
Chromium, total	< 0.00050	MAC = 0.05	0.00050	mg/L	2022-02-11	
Copper, total	0.0110	MAC = 2	0.00040	mg/L	2022-02-11	
Iron, total	0.811	AO ≤ 0.3	0.010	mg/L	2022-02-11	
Lead, total	< 0.00020	MAC = 0.005	0.00020	mg/L	2022-02-11	
Magnesium, total	3.69	None Required	0.010	mg/L	2022-02-11	
Manganese, total	0.00569	MAC = 0.12	0.00020	mg/L	2022-02-11	
Potassium, total	1.93	N/A	0.10	mg/L	2022-02-11	
Selenium, total	< 0.00050	MAC = 0.05	0.00050	mg/L	2022-02-11	
Sodium, total	9.06	AO ≤ 200	0.10	mg/L	2022-02-11	
Strontium, total	0.225	MAC = 7	0.0010	mg/L	2022-02-11	
Uranium, total	0.0734	MAC = 0.02	0.000020	mg/L	2022-02-11	



TEST RESULTS


REPORTED TO Century 21 Horizon West (Princeton)
PROJECT Analysis for Lee Mowry

WORK ORDER 22B0823
REPORTED 2022-02-14 14:27

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
175 Link Lake Road Essential Drinking Water Test (22B0823-01) Matrix: Water Sampled: 2022-02-05 10:00, Continued						
Total Metals, Continued						
Zinc, total	< 0.0040	AO ≤ 5		0.0040 mg/L		2022-02-11

Sample Qualifiers:

HT2 The 15 minute recommended holding time (from sampling to analysis) has been exceeded - field analysis is recommended.



APPENDIX 1: SUPPORTING INFORMATION

REPORTED TO Century 21 Horizon West (Princeton)
PROJECT Analysis for Lee Mowry


WORK ORDER 22B0823
REPORTED 2022-02-14 14:27

Analysis Description	Method Ref.	Technique	Accredited	Location
Alkalinity in Water	SM 2320 B* (2017)	Titration with H ₂ SO ₄	✓	Kelowna
Anions in Water	SM 4110 B (2017)	Ion Chromatography	✓	Kelowna
Coliforms, Total in Water	SM 9222* (2017)	Membrane Filtration / Chromocult Agar	✓	Kelowna
Conductivity in Water	SM 2510 B (2017)	Conductivity Meter	✓	Kelowna
Cyanide, SAD in Water	ASTM D7511-12	Flow Injection with In-Line UV Digestion and Amperometry	✓	Kelowna
E. coli in Water	SM 9222* (2017)	Membrane Filtration / Chromocult Agar	✓	Kelowna
Hardness in Water	SM 2340 B* (2017)	Calculation: 2.497 [total Ca] + 4.118 [total Mg] (Est)	✓	N/A
pH in Water	SM 4500-H+ B (2017)	Electrometry	✓	Kelowna
Solids, Total Dissolved in Water	SM 1030 E (2017)	SM 1030 E (2011)		N/A
Total Metals in Water	EPA 200.2 / EPA 6020B	HNO ₃ +HCl Hot Block Digestion / Inductively Coupled Plasma-Mass Spectroscopy (ICP-MS)	✓	Richmond
Turbidity in Water	SM 2130 B (2017)	Nephelometry	✓	Kelowna

Note: An asterisk in the Method Reference indicates that the CARO method has been modified from the reference method

Glossary of Terms:

RL	Reporting Limit (default)
<	Less than the specified Reporting Limit (RL) - the actual RL may be higher than the default RL due to various factors
AO	Aesthetic Objective
CFU/100 mL	Colony Forming Units per 100 millilitres
MAC	Maximum Acceptable Concentration (health based)
mg/L	Milligrams per litre
NTU	Nephelometric Turbidity Units
OG	Operational Guideline (treated water)
pH units	pH < 7 = acidic, pH > 7 = basic
µS/cm	Microsiemens per centimetre
ASTM	ASTM International Test Methods
EPA	United States Environmental Protection Agency Test Methods
SM	Standard Methods for the Examination of Water and Wastewater, American Public Health Association



APPENDIX 1: SUPPORTING INFORMATION

REPORTED TO Century 21 Horizon West (Princeton)
PROJECT Analysis for Lee Mowry

WORK ORDER 22B0823
REPORTED 2022-02-14 14:27

General Comments:

The results in this report apply to the samples analyzed in accordance with the Chain of Custody document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Samples will be disposed of 30 days after the test report has been issued or once samples expire, whichever comes first. Longer hold is possible if agreed to in writing. The quality control (QC) data is available upon request

Results in **Bold** indicate values that are above CARO's method reporting limits. Any results that are above regulatory limits are highlighted **red**. Please note that results will only be highlighted red if the regulatory limits are included on the CARO report. Any Bold and/or highlighted results do not take into account method uncertainty. If you would like method uncertainty or regulatory limits to be included on your report, please contact your Account Manager: teamcaro@caro.ca

Please note any regulatory guidelines applied to this report are added as a convenience to the client, at their request, to help provide some initial context to analytical results obtained. Although CARO makes every effort to ensure accuracy of the associated regulatory guideline(s) applied, the guidelines applied cannot be assumed to be correct due to a variety of factors and as such CARO Analytical Services assumes no liability or responsibility for the use of those guidelines to make any decisions. The original source of the regulation should be verified and a review of the guideline(s) should be validated as correct in order to make any decisions arising from the comparison of the analytical data obtained to the relevant regulatory guideline for one's particular circumstances. Further, CARO Analytical Services assumes no liability or responsibility for any loss attributed from the use of these guidelines in any way.